LIGHT F	TIXTURE SCHE	DULE		
TYPE	SYMBOL	DESCRIPTION	MANUFACTURER	REFERENCE CATALOG #
A		2X4 LED RECESSED TROFFER. 37W, 4677 LUMENS, 3500K CCT, 80 CRI. 0-10V DIMMING.	LITHONIA	CPX 2X4 ALO8 SWW7
AE		2X4 LED RECESSED TROFFER. 37W, 4677 LUMENS, 3500K CCT, 80 CRI. 0-10V DIMMING. PROVIDE 90 MIN BATTERY BACKUP.	LITHONIA	CPX 2X4 ALO8 SWW7 IE10WCP
С	¢	6" LED RECESSED DOWNLIGHT. 13W, 1378 LUMENS, 3500K CCT. IC RATED, 0-10V DIMMING.	LITHONIA	LBR6 NCH ALO2 SWW1 AR LSS WD MVOLT UGZ
CE	<b>*</b>	6" RECESSED LED DOWNLIGHT. 13W, 1378 LUMENS, 3500K, CCT. IC RATED, 0-10V DIMMING. 90 MIN BATTERY BACKUP.	LITHONIA	LBR6 NCH ALO2 SWW1 AR LSS WD MVOLT UGZ E10WCPR
EX	×	LED EXIT SIGN, BRUSHED ALUMINUM FACE WITH RED LETTERS. UNIVERSAL FACE AND MOUNTING. 90 MIN BATTERY BACKUP.	LIFESAFETY LIGHTING	LSXDC 3 R B A EM SDT
LE	,	4' LED VANITY FIXTURE 24W, 2288 LUMENS, 4000K CT, 80 CRI. 0-10V DIMMING. PROVIDE 90 MIN BATTERY BACKUP.	LITHONIA	ACLSWT M4 DLS 40 U HE M5 B 1 D E1 Q
W	ф	EXTERIOR LED WALL PACK. 47W, 5896 LUMENS, 4000K CCT. WET LOCATION.	LITHONIA	WPX2 LED 40K MVOLT DBLXD

EQUIVALENT ALTERNATE LIGHT FIXTURES MAY BE PROVIDED FOR BIDDING PURPOSES. THE ENGINEER DOES NOT TAKE RESPONSIBILITY FOR ENSURING ALTERNATE LIGHT FIXTURES USED FOR BIDDING ARE EQUAL; THE CONTRACTOR SHALL BE RESPONSIBLE FOR ENSURING ALTERNATE FIXTURES ARE EQUIVALENT TO THOSE SPECIFIED PRIOR TO BID. THE WINNING BID PACKAGE SHALL BE SUBMITTED TO THE ENGINEER FOR REVIEW IN ACCORDANCE WITH THE SPECIFICATIONS.

	ELECTRICAL A	BBR	EVIATIONS
AC	ABOVE COUNTERTOP	МС	MECHANICAL CONTRACTOR
AFF	ABOVE FINISH FLOOR	MCA	MINIMUM CIRCUIT AMPS
AFG	ABOVE FINISH GRADE	MDP	MAIN DISTRIBUTION PANEL
ANNC	ANNUNICIATOR	MTD	MOUNTED
CC	CONTROLS CONTRACTOR	NIC	NOT IN CONTRACT
DF	DRINKING FOUNTAIN	occ	OCCUPANCY
EC	ELECTRICAL CONTRACTOR	PC	PLUMBING CONTRACTOR
EF	EXHAUST FAN	PNL	PANEL
EX	EXISTING	SPST	SINGLE POLE SINGLE THRO
EXR	EXISTING RELOCATED	TTB	TELEPHONE TERMINAL BOAR
GC	GENERAL CONTRACTOR	TYP	TYPICAL
GFI	GROUND FAULT INTERRUPT	WG	WIRE GUARD
HP	HORSEPOWER	WP	WEATHER PROOF
IBC	INTERNATIONAL BUILDING CODE	20A	20 AMP
IG	ISOLATED GROUND	ø	PHASE
LV	LOW VOLTAGE	3W	3 WIRE
LVRP	LV RELAY PANEL	1P20A	SINGLE POLE 20 AMP

SWITCH LEGEND	
SYMBOL	DESCRIPTION
\$	20A, 120/277V SPST SWITCH
\$ <sub>a</sub>	20A, 120/277V LETTER INDICATES GROUP
\$3	20A, 120/277V 3-WAY
\$4	20A, 120/277V 4-WAY
\$ <sub>D</sub>	DIMMER SWITCH
\$ĸ	KEY OPERATED SWITCH
\$ <sub>oc</sub>	OCCUPANCY SENSOR SWITCH
	•

### GENERAL NOTE: SEE SPECIFICATIONS FOR MANUFACTURERS

OCC SENSOR SCHEDULE					
SYMBOL	DESCRIPTION				
<u>©</u>	MULTI-TECHNOLOGY, CEILING MOUNTED OCCUPANCY SENSOR CAPABLE OF DISABLING AUTO ADAPTING FEATURE. PROVIDE WITH RELAY/POWER PACKS AS REQUIRED PER PLAN. (LOW VOLTAGE)				

GENERAL NOTES:

1. E.C. SHALL CONTACT ARCHITECT FOR COLOR SELECTION PRIOR TO ORDER OF ANY SENSOR.

2. FOR CEILING SPACES 14 FT. A.F.F. PIR TYPE CEILING MOUNTED SENSORS SHALL BE USED.

3. WALL MOUNTED DEVICES TO MATCH MANUAL LIGHTING

RECEPTACLE SCHEDULE					
SYMBOL	DESCRIPTION				
φ	DUPLEX RECEPTACLE				
Ϋ́P	20A, 120V, 2P, 3W GROUNDING DUPLEX GFCI RECEPTACLE — WEATHER PROOF (IN USE COVER)				
#	QUADPLEX RECEPTACLE				

GENERAL NOTE: SEE SPECIFICATIONS FOR MANUFACTURERS

### GENERAL ELECTRICAL NOTES CONTRACTOR TO VERIFY EXISTING ELECTRICAL CONDITIONS AND NOTIFY ARCHITECT/ENGINEER OF ANY ELECTRICAL OR CODE ISSUES PRIOR TO BID. CONTRACTOR IS RESPONSIBLE FOR PROVIDING A COMPLETE AND

OPERATIONAL CODE COMPLIANT SYSTEM. ALL WORK SHALL BE IN CONFORMANCE WITH NATIONAL, STATE, AND LOCAL

ELECTRICAL CONTRACTOR SHALL COORDINATE WORK WITH ALL OTHER CONTRACTORS & LOCAL UTILITY. E.C. SHALL CONTACT LOCAL UTILITY FOR EXACT SERVICE REQUIREMENTS TO INCLUDE BUT NOT LIMITED TO TRANSFORMER, METERING AND CABLING. LOCAL UTILITY REQUIREMENTS SUPERSEDE DRAWINGS AND SPECIFICATIONS.

SEE ARCHITECTURAL AND MECHANICAL DRAWINGS FOR ADDITIONAL REQUIREMENTS.

CODES AND/OR ORDINANCES.

ELECTRICAL DRAWINGS ARE DIAGRAMMATIC ONLY. THEY ARE INTENDED TO GIVE APPROXIMATE LOCATIONS AND OVERALL DESIGN INTENT. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR PRODUCTS, MATERIALS, AND ELECTRICAL METHODS WHICH HAVE NOT BEEN SHOWN OR INDICATED BUT ARE REQUIRED FOR A COMPLETE SYSTEM TO THE STANDARDS OF THE INDUSTRY.

INSTALL LIGHTING FIXTURES IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS. PROVIDE SUPPORTING DEVICES FOR ADEQUATE SUPPORT OF FIXTURES FROM STRUCTURE.

UPON COMPLETION OF THE ELECTRICAL WORK, THE INSTALLATION SHALL BE TESTED FOR CONTINUITY, GROUNDS, AND SHORT CIRCUITS. THE ELECTRICAL CONTRACTOR SHALL DEMONSTRATE PROPER PERFORMANCE OF ALL SYSTEMS. ALL DEFECTIVE WORK OR MATERIALS SHALL BE REPLACED OR REPAIRED AS NECESSARY AND RETESTED.

ELECTRICAL RACEWAYS THAT PENETRATE FIRE RATED ASSEMBLIES SHALL BE SLEEVED AND SEALED AS PER THE LOCAL BUILDING CODE.

ELECTRICAL LEGEND					
<b>—</b>	PANEL BOARD				
	DISTRIBUTION PANEL BOARD				
T	TRANSFORMER				
D	UTILITY METER				
СВ	SEPARATE CIRCUIT BREAKER				
마	DISCONNECT				
D'	FUSED DISCONNECT SWITCH				
<b>⊿</b> ↓	EMERGENCY FUSED DISCONNECT SWITCH				
$\boxtimes$	MOTOR STARTER/CONTRACTOR				
⊠h	COMBINATION MOTOR STARTER				
H●	PUSH BUTTON STATION AS NOTED				
Р	PULL BOX, SIZE AS REQUIRED BY CODE				
lacktriangledown	ELECTRICAL CONNECTION				
<i>/</i> C/	MOTOR CONNECTION				

_	
	ELECTRICAL SHEET INDEX
E000	ELECTRICAL TITLE SHEET
E001	ELECTRICAL SITE PLAN
E101	ELECTRICAL LIGHTING PLAN
E201	ELECTRICAL POWER PLAN
E202	ELECTRICAL POWER PLAN — ROOF
E401	ELECTRICAL ONE-LINE DIAGRAM AND SCHEDULES
E501	ELECTRICAL DETAILS SHEET

HOME RUN TO PANEL BOARD



201 N. BROADWAY SUITE 210 MOORE, OK. 73160 405.735.3477 AGP@theAGP.net www.theAGP.net

KFC ENGINEERING

STRUCTURAL

SALAS O'BRIEN MECHANICAL / ELECTRICAL



GT drawn by TVO checked by SEPTEMBER 2023

revisions

MOORE PUBLIC SCHOOLS BOARD OF EDUCATION MOORE, OKLAHOMA



OFFICE ADDITION **FAIRVIEW ELEMENTARY SCHOOL** 

sheet no:




Salas O'Brien Project Number: 2023-04386-00

Norman, OK 73072 Salas O'Brien Registration: CA# 7058 Expiration Date: 6/30/2025

AGP EXPRESSLY RESERVES ITS COPYRIGHT AND OTHER PROPERTY RIGHTS OF ALL PLANS AND DRAWINGS DESIGNED AND/OR PRODUCED. PLANS AND DRAWINGS ARE NOT TO BE REPRODUCED IN ANY FORM OR MANNER WITHOUT THE EXPRESSED WRITTEN

CONSENT OF AGP.

OWNERSHIP USE OF DOCUMENTS:



## **GENERAL NOTES**

PANEL AND BREAKER INFORMATION IS BASED ON EXISTING CONDITIONS AT THE TIME OF SITE INVESTIGATION. EC SHALL FIELD VERIFY PANEL NAMES, LOCATIONS, SPACES, ETC. AND MAKE ANY CHANGES NECESSARY TO COMPLETE WORK.

. EC SHALL COORDINATE WITH OWNER FOR FINAL CONDUIT AND RECEPTACLE LOCATIONS.

EACH CIRCUIT SHALL BE PROVIDED A 20A BREAKER FROM RESPECTIVE SOURCE PANEL.

## **KEYED NOTES**

1 APPROXIMATE LOCATION OF NEW PANEL 'L'. REFER TO SHEET E401 FOR ADDITIONAL INFORMATION REGARDING NEW CONNECTIONS.

2 APPROXIMATE LOCATION OF EXISTING PANEL 'M2'. PROVIDE NEW 60A/3PH BREAKER TO SERVE NEW PANEL 'L'. REFER TO SHEET E401 FOR ADDITIONAL INFORMATION REGARDING NEW CONNECTIONS.

PROPOSED CONDUIT FEED FOR NEW SUBPANEL 'L' FROM EXISTING 'M2'.
COORDINATE EXACT CONDUIT ROUTE WITH ARCHITECT, CIVIL, AND OTHER
TRADES PRIOR TO ROUGH—IN. REFER TO SHEET E401 FOR WIRE AND
CONDUIT SIZE AND FOR ADDITIONAL INFORMATION REGARDING NEW
CONNECTIONS.



201 N. BROADWAY SUITE 210 MOORE, OK. 73160 405.735.3477 AGP@theAGP.net www.theAGP.net

KFC ENGINEERING

STRUCTURAL

SALAS O'BRIEN

MECHANICAL / ELECTRICAL



drawn by
TVO
checked by

SEPTEMBER 2023

. .


MOORE PUBLIC SCHOOLS BOARD OF EDUCATION MOORE, OKLAHOMA



OFFICE ADDITION
FAIRVIEW
ELEMENTARY SCHOOL

sheet no:


E001



Salas O'Brien Project Number: 2023-04386-00

OWNERSHIP USE OF DOCUMENTS:

AGP EXPRESSLY RESERVES ITS
COPYRIGHT AND OTHER PROPERTY
RIGHTS OF ALL PLANS AND DRAWINGS
DESIGNED AND/OR PRODUCED. PLANS
AND DRAWINGS ARE NOT TO BE
REPRODUCED IN ANY FORM OR MANNER
WITHOUT THE EXPRESSED WRITTEN
CONSENT OF AGP.



1 ELECTRICAL LIGHTING PLAN
SCALE: 1/4" = 1'-0"

### **GENERAL NOTES**

- 1. OCCUPANCY SENSOR LOCATIONS ARE FOR DESIGN INTENT ONLY. LOCATE OCCUPANCY SENSORS PER MANUFACTURERS WRITTEN INSTALLATION INSTRUCTIONS.
- COORDINATE EXACT LOCATIONS AND MOUNTING HEIGHTS OF LIGHT FIXTURES WITH HVAC EQUIPMENT AND OTHER DEVICES/EQUIPMENT.
- COORDINATE LIGHT SWITCHES WITH THERMOSTATS AND OTHER WALL MOUNTED DEVICES.
- 4. COORDINATE EXTERIOR FIXTURE MOUNTING HEIGHT WITH ARCHITECT AND OWNER PRIOR TO ROUGH IN.
- NEW EXTERIOR LIGHTING SHALL BE CONTROLLED BY NEAREST EXISTING EXTERIOR LIGHTING SYSTEM VIA RELAY/CONTACTOR.

## **KEYED NOTES**

1 EXISTING FIXTURES SHALL BE REMOVED AND REPLACED AS SHOWN.
EXISTING CIRCUITS AND CONTROLS SHALL REMAIN.

NEW LIGHT FIXTURE SHALL BE POWERED AND CONTROLLED FROM EXISTING CORRIDOR LIGHTING. EC SHALL PROVIDE ALL WIRING, CONDUITS, AND DEVICES NECESSARY FOR NEW LIGHT FIXTURE CONNECTIONS.

AGP
the Abla Griffin
Partnership L.L.C.

201 N. BROADWAY SUITE 210 MOORE, OK. 73160 405.735.3477 AGP@theAGP.net www.theAGP.net

KFC ENGINEERING

STRUCTURAL

SALAS O'BRIEN

MECHANICAL / ELECTRICAL



GT
drawn by
TVO
checked by

SEPTEMBER 2023
date


MOORE PUBLIC SCHOOLS BOARD OF EDUCATION MOORE, OKLAHOMA



OFFICE ADDITION
FAIRVIEW
ELEMENTARY SCHOOL

shee


E101



Salas O'Brien Project Number: 2023-04386-00

OWNERSHIP USE OF DOCUMENTS:

AGP EXPRESSLY RESERVES ITS
COPYRIGHT AND OTHER PROPERTY
RIGHTS OF ALL PLANS AND DRAWINGS
DESIGNED AND/OR PRODUCED. PLANS
AND DRAWINGS ARE NOT TO BE
REPRODUCED IN ANY FORM OR MANNER
WITHOUT THE EXPRESSED WRITTEN
CONSENT OF AGP.



**GENERAL NOTES** 

COORDINATE EXACT LOCATION OF DEVICES SHOWN WITH OTHER EQUIPMENT. COORDINATE EXACT LOCATIONS OF CEILING MOUNTED DEVICES WITH LIGHTS, HVAC EQUIPMENT, AND OTHER DEVICES.

2. COORDINATE WITH MC AND PROVIDE ALL RELAYS, CONNECTIONS, AND ALL DEVICES NECESSARY TO INTERLOCK EXHAUST FANS, DAMPERS, ETC WITH PROPER CONTROL DEVICES.

3. COORDINATE EXACT LOCATIONS OF MECHANICAL EQUIPMENT WITH MECHANICAL CONTRACTOR.

I. COORDINATE EXACT LOCATIONS OF PLUMBING EQUIPMENT WITH PLUMBING CONTRACTOR.

KEYED NOTES

1 PROVIDE 120V DEDICATED CONNECTION FOR COPIER/PRINTER.

COORDINATE FINAL LOCATION AND REQUIREMENTS WITH ARCHITECT/OWNER PRIOR TO ROUGH-IN.



201 N. BROADWAY SUITE 210 MOORE, OK. 73160 405.735.3477 AGP@theAGP.net www.theAGP.net

KFC ENGINEERING

STRUCTURAL

SALAS O'BRIEN

MECHANICAL / ELECTRICAL



GT
drawn by
TVO
checked by
SEPTEMBER 2023
date

MOORE PUBLIC SCHOOLS BOARD OF EDUCATION MOORE, OKLAHOMA



OFFICE ADDITION
FAIRVIEW
ELEMENTARY SCHOOL

she

E201




Salas O'Brien Registration: CA# 7058 Expiration Date : 6/30/2025

Salas O'Brien Project Number: 2023-04386-00

OWNERSHIP USE OF DOCUMENTS:

AGP EXPRESSLY RESERVES ITS
COPYRIGHT AND OTHER PROPERTY
RIGHTS OF ALL PLANS AND DRAWINGS
DESIGNED AND/OR PRODUCED. PLANS
AND DRAWINGS ARE NOT TO BE
REPRODUCED IN ANY FORM OR MANNER
WITHOUT THE EXPRESSED WRITTEN
CONSENT OF AGP.



1 ELECTRICAL POWER PLAN - ROOF

SCALE: 1/4" = 1'-0"



## ROOF POWER GENERAL NOTES

COORDINATE EXACT LOCATIONS OF DEVICES SHOWN WITH OTHER EQUIPMENT.

- 2. COORDINATE WITH MECHANICAL CONTRACTOR AND PROVIDE ALL RELAYS, CONNECTIONS, AND ALL DEVICES NECESSARY TO INTERLOCK EXHAUST FANS, DAMPERS, ETC WITH PROPER DEVICES.
- COORDINATE EXACT LOCATIONS OF MECHANICAL EQUIPMENT WITH MECHANICAL CONTRACTOR.
- FIRMLY MOUNT WEATHERPROOF 120V CONVENIENCE OUTLET ON UNISTRUT/KINDORF. COORDINATE WITH OTHER TRADES PRIOR TO ROUGH-IN.



201 N. BROADWAY SUITE 210 MOORE, OK. 73160 405.735.3477 AGP@theAGP.net www.theAGP.net

KFC ENGINEERING STRUCTURAL

SALAS O'BRIEN MECHANICAL / ELECTRICAL



drawn by TVO checked by SEPTEMBER 2023

MOORE PUBLIC SCHOOLS BOARD OF EDUCATION MOORE, OKLAHOMA



OFFICE ADDITION **FAIRVIEW ELEMENTARY SCHOOL** 


sheet no:

E202



OWNERSHIP USE OF DOCUMENTS:

AGP EXPRESSLY RESERVES ITS COPYRIGHT AND OTHER PROPERTY RIGHTS OF ALL PLANS AND DRAWINGS DESIGNED AND/OR PRODUCED. PLANS AND DRAWINGS ARE NOT TO BE Salas O'Brien Registration: CA# 7058 Expiration Date: 6/30/2025 REPRODUCED IN ANY FORM OR MANNER WITHOUT THE EXPRESSED WRITTEN CONSENT OF AGP. Salas O'Brien Project Number: 2023-04386-00



MECHANICAL EQ	JIPMENT SCHEDULE										
CALLOUT	DESCRIPTION	VOLTS	HP	KVA	MCA	MOCP	CIRCUIT	WIRE CALLOUT	DISCONNECT	DISC PROV BY	DISC INST BY
CU-1	CONDENSING UNIT	208/120V 2P 3W		5.23	31.4	50	L-17,19	3/4"C,2#8,#8N,#10G	NON-FUSED	MC	EC
F-1	GAS FURNACE	120V 1P 2W		1.92	20	30	L-15	3/4"C,1#12,#12N,#12G	NON-FUSED	МС	EC

	FEED	DER SCH	HEDULE	
AMPS	CONDUIT SIZE 4W	CONDUIT SIZE 3W	PHASE CONDUCTORS	EQUIP. GROUND CONDUCTORS
20	3/4"	3/4"	#12	#12
25	3/4"	3/4"	#10	#10
30	3/4"	3/4"	#10	#10
35	1"	3/4"	#8	#10
40	1"	3/4"	#8	#10
45	1"	1"	#6	#10
50	1"	1"	#6	#10
60	1 1/4"	1 1/4"	#4	#10
70	1 1/4"	1 1/4"	#4	#8
80	1 1/4"	1 1/4"	#2	#8
90	1 1/2"	1 1/4"	#2	#8
100	1 1/2"	1 1/2"	#1	#8
110	2"	1 1/2"	#1	#6
125	2"	1 1/2"	#1/0	#6
150	2"	1 1/2"	#1/0	#6
175	2"	2"	#2/0	#6
200	2"	2"	#3/0	#6
225	2 1/2"	2"	#4/0	#4
250	3"	2 1/2"	250 kcmil	#4
300	3"	3"	350 kcmil	#4
350	3 1/2"	3"	500 kcmil	#3
400	(2) 2"	(2) 2"	2 SETS OF #3/0	#3

- FEEDER SIZES ARE ON THE PLAN WHERE 60 REFERS TO A 60A FEEDER WITHOUT NEUTRAL AND 60N REFERS TO A 60A FEEDER WITH NEUTRAL. . SOME FEEDER SIZES DO NOT MATCH BREAKER SIZE DUE TO UP-SIZING OF THE FEEDER FOR VOLTAGE DROP.
- . CONDUITS ARE SIZED PER NEC TABLES FOR THHN/THWN AND MAY BE UPSIZED FOR EASE OF PULLING OR DOWNSIZED AS ALLOWED PER NEC FOR CONDUIT TYPE(S) BEING INSTALLED.
- . ALL CONDUCTORS 100A AND LESS ARE SIZED PER 60 DEGREE LUGS, EC MAY SIZE CONDUCTORS FOR ACTUAL RATING OF LUGS PER NEC.

## **EXISTING LOAD ANALYSIS**

EXISTING PANEL 'MDP' LOAD ANALYSIS:

PEAK LOAD ASK REPORTED BY UTILITY: 529.4A/PHASE (220KVA) 529.4A\*1.25 (PER NEC 220.87) = 661.5A/PHASE (274.8KVA)

+DESIGN LOAD =  $\sim$ 695.5A/PHASE(289.1KVA)

=> <u>~695.5A (289.1KVA) MAX ON THE PANEL 'MDP' 1600A.</u>

## **GENERAL NOTES**

- THE EXISTING LOAD FOR PANEL 'M2' WAS UNABLE TO BE VERIFIED DURING DESIGN, EC SHALL PERFORM A 30 DAY LOAD STUDY ON THE PANEL PRIOR TO PERFORMING ANY WORK IN ORDER TO DETERMINE THE EXISTING PEAK LOAD IN ACCORDANCE WITH NEC 220.87 (1). FINAL RESULTS SHALL BE REPORTED TO THE ENGINEER PRIOR TO BEGINNING WORK.
- AIC RATINGS ARE ESTIMATED BASED ON AVAILABLE DATA DURING DESIGN. CONTRACTOR TO VERIFY AVAILABLE FAULT CURRENT WITH UTILITY.
- FAULT CURRENT, ARC FLASH, AND COORDINATION STUDY SHALL BE PERFORMED BY A THIRD PARTY ONCE EXACT PANEL PLACEMENT AND DISTANCES ARE DETERMINED. REFER TO SPECIFICATIONS SECTION 26 0573 FOR MORE INFORMATION.
- PROVIDE A MINIMUM OF 10 SPARE 1P20A BREAKERS FOR EACH 120V SUB-PANEL.

the Abla Griffin

Partnership L.L.C.

201 N. BROADWAY

SUITE 210

MOORE, OK. 73160

405.735.3477

AGP@theAGP.net

www.theAGP.net

KFC ENGINEERING

SALAS O'BRIEN

MECHANICAL / ELECTRICAL

STRUCTURAL

drawn by	
TVO	
checked by	/
SEPTEMBE date	ER 2023

MOORE PUBLIC SCHOOLS **BOARD OF EDUCATION** MOORE, OKLAHOMA



OFFICE ADDITION **FAIRVIEW ELEMENTARY SCHOOL** 

sheet no:

OWNERSHIP USE OF DOCUMENTS:


WITHOUT THE EXPRESSED WRITTEN

CONSENT OF AGP.



Salas O'Brien Project Number: 2023-04386-00

AGP EXPRESSLY RESERVES ITS COPYRIGHT AND OTHER PROPERTY RIGHTS OF ALL PLANS AND DRAWINGS DESIGNED AND/OR PRODUCED. PLANS Norman, OK 73072 AND DRAWINGS ARE NOT TO BE Salas O'Brien Registration: CA# 7058 REPRODUCED IN ANY FORM OR MANNER Expiration Date: 6/30/2025



1 ELECTRICAL ONE - LINE DIAGRAM
NO SCALE

EXISTING UTILITY

TRANSFORMER

**EXISTING** 

TRANSFORMER PAD

SECONDARY CABLE

CT CABINET

METER METER

EXISTING FEEDER CABLE


EXISTING 'MDP' 1600AMP BUS

 $240V/120V - 3\emptyset, 4W$ 


EXISTING XFR 240/120V, 3Ø,4W

208Y/120V, 3Ø,4W

G—●




## 3 TYP.TROFFER POWER DETAIL NO SCALE




# 4 IC LIGHT FIXTURE DETAIL NO SCALE


## 2 MULTIPLE BOX SUPPORT DETAIL NO SCALE




6 JUNCTION BOX DETAIL
NO SCALE



SOME EXAMPLES: - 3/4" PLASTER RING FOR SINGLE LAYER 5/8" GYPŚUM BOARD WALL FINISH – 1" PLASTER RING FOR TWO LAYER WALL FINISH 1/2"



CADDY BOX SUPPORT #RBS24 - FOR STUDS 24" ON CENTER.



WOOD OR METAL WALL STUD —

BOX SUPPORT

CADDY QUICK MOUNT BOX SUPPORT CADDY BOX SUPPORT #H23, H4,

ELECTRICAL CONTRACTOR TO SIZE DEPTH

SOME EXAMPLES:
- 3/4" PLASTER RING FOR SINGLE LAYER 5/8"

- 1" PLASTER RING FOR TWO LAYER WALL FINISH 1/2" OVER 1/4"

COMBUSTABLE WALLS

NON-COMBUSTABLE WALLS

OF PLASTER RING TO INCLUDE BOX

SUPPORT OFFSET, THICKNESS OF DRYWALL AND WALLCOVERING (IF USED).

GYPSUM BOARD WALL FINISH

FOR ALL COMBUSTIBLE WALLS PLASTER RING MUST BE FLUSH WITH OUTER SURFACE OF

OUTER SURFACE

OF FINISHED WALL

FOR ALL NON-COMBUSTIBLE

WITHIN 1/8" FROM OUTER

WALLS PLASTER RING MUST BE

BOX SUPPORT DETAIL

NO SCALE

H53 (AS APPROPRIATE) -

OFFSET -

5 TYP OUTLET MOUNTING DETAIL
NOT TO SCALE



201 N. BROADWAY SUITE 210 MOORE, OK. 73160 405.735.3477 AGP@theAGP.net www.theAGP.net

KFC ENGINEERING STRUCTURAL

SALAS O'BRIEN MECHANICAL / ELECTRICAL



drawn by TVO checked by SEPTEMBER 2023 revisions

MOORE PUBLIC SCHOOLS **BOARD OF EDUCATION** MOORE, OKLAHOMA



OFFICE ADDITION **FAIRVIEW ELEMENTARY SCHOOL** 

sheet no:

E501



Salas O'Brien Project Number: 2023-04386-00

Expiration Date: 6/30/2025

OWNERSHIP USE OF DOCUMENTS:

AGP EXPRESSLY RESERVES ITS COPYRIGHT AND OTHER PROPERTY RIGHTS OF ALL PLANS AND DRAWINGS DESIGNED AND/OR PRODUCED. PLANS AND DRAWINGS ARE NOT TO BE REPRODUCED IN ANY FORM OR MANNER WITHOUT THE EXPRESSED WRITTEN CONSENT OF AGP.