



GENERAL NOTES

1. EC SHALL FIELD VERIFY EXISTING CONDITIONS PRIOR TO ALL WORK.
2. CONDUIT ROUTE SHOWN IS ONLY TO CONVEY DESIGN INTENT. EC SHALL DETERMINE FINAL ROUTING OF NEW CONDUIT AFTER FIELD VERIFYING EXISTING CONDITIONS.

KEYED NOTES

- 1 EXISTING OG&E METER #: 53390586G
- 2 EXISTING 1200A PANEL 'MDPA' SHALL BE REMOVED AND REPLACED WITH NEW 1200A 1-LINE STYLE PANELBOARD. EXISTING SUBPANELS SHALL ALL REMAIN INTACT AND BE FED FROM NEW BREAKERS. REFER TO SHEET E401 FOR ADDITIONAL INFORMATION REGARDING EXISTING MDPA AND CONNECTIONS.
- 3 EXISTING 1000A BREAKER ON MDP SHALL REMAIN.

AGP
the Abla Griffin
Partnership L.L.C.

201 N. BROADWAY
SUITE 210
MOORE, OK. 73160
405.735.3477
AGP@theAGP.net
www.theAGP.net

KFC ENGINEERING
STRUCTURAL

SALAS O'BRIEN
MECHANICAL / ELECTRICAL



DW
drawn by
TVO
checked by
SEPTEMBER 2021
date

revisions

MOORE PUBLIC SCHOOLS
BOARD OF EDUCATION
MOORE, OKLAHOMA



CLASSROOM ADDITION
HIGHLAND EAST
JUNIOR HIGH SCHOOL

sheet no:

E001

