

**MOORE PUBLIC SCHOOLS -  
HIGHLAND WEST JUNIOR HIGH SCHOOL –  
STEM & OFFICE ADDITION**

Moore Public Schools - Moore, Oklahoma  
AGP - Moore, Oklahoma

---

**CONSTRUCTION BULLETIN NO. 6**

March 13, 2024

---

1. ALL PRIMUS CORES / CYLINDERS TO REMAIN AS SPECIFIED – SCHLAGE 20-740
2. ALL CLASSIC CORES / CYLINDERS TO BE SCHLAGE 23-030 IN LIEU OF CORES / CYLINDERS SPECIFIED.
3. REVISE OTHER HARDWARE, LOCKSETS, CORES, ETC. AS PER THE ATTACHED REVISED SCHEDULE.

END OF CONSTRUCTION BULLETIN NO. 6

# Hardware Schedule

Project ID: 23OK1521-CH - Highland West Junior High Classroom Addition

## Heading #: 1.0

## EXT. PAIR ALD/ALF

1	PRA/PRI	Door: O1	Exterior From Vestibule 27	RHRA/LHR
1	PRA/PRI	Door: O2	Exterior From Vestibule 27	RHRA/LHR
2-3' 0" x 7' 0" x 1 3/4" ALD/ALF				
4 EA	Intermediate Pivot	7215-INT	US26D	(PV-1) Ives
4 Set	Pivot Set	7215-SET	US26D	(PV-2) Ives
2 EA	Electric Power Transfer	EPT10	.689	(PT-1) Von Duprin
2 EA	Mullion	KR4954 7'6	.689	(MU-1) Von Duprin
2 EA	Rim Exit Device	.CD 99.NLOP .110MD-NL	.626	(ED-6) Von Duprin
2 EA	Rim Exit Device	.QEL 99.EO	.626	(ED-1) Von Duprin
2 EA	Cylinder	20-061 .ICX	.626	(CY-2) Schlage
4 EA	Cylinder	20-740	.626	(CY-3) Schlage
2 EA	Cylinder	20-057 .ICX	.626	(CY-1) Schlage
4 EA	Door Pull	8190HD-0 O	630	(PP-1) Ives
4 EA	Surface Closer	4040XP .SCUSH	.689	(CL-1) LCN Closers
4 EA	Drop Plate	4040XP-18PA	.689	(CL-2) LCN Closers
4 EA	Shoe	4040XP-30	.689	(CL-3) LCN Closers
4 EA	Spacer	4040XP-61	.689	(CL-4) LCN Closers
2 EA	Threshold	896V x 72"		(TH-1) National Guard
4 EA	Sweep	C627A x 36"		(SW-1) National Guard

-ADDED EPT TO POWER ELECTRIFIED EXIT DEVICE. ADVISE IF ACCEPTABLE???????

-MEETING STILE WEATHERSTRIP BY DOOR MANUFACTURER.

-PERIMETER SEAL BY DOOR MANUFACTURER.

-CARD READER AND POWER SUPPLY BY SECURITY CONTRACTOR.

OK - AGP

## Heading #: 2.0

## INT. PAIR ALD/ALF

1	PRA/PRI	Door: O3	Vestibule 27 From Corridor 28	RHRA/LHR
1	PRA/PRI	Door: O4	Vestibule 27 From Corridor 28	RHRA/LHR
2-3' 0" x 7' 0" x 1 3/4" ALD/ALF				
4 EA	Intermediate Pivot	7215-INT	US26D	(PV-1) Ives
4 Set	Pivot Set	7215-SET	US26D	(PV-2) Ives
2 EA	Electric Power Transfer	EPT10	.689	(PT-1) Von Duprin
2 EA	Mullion	KR4954 7'6	.689	(MU-1) Von Duprin
2 EA	Rim Exit Device	.CD 99.NLOP .110MD-NL	.626	(ED-6) Von Duprin
2 EA	Rim Exit Device	.QEL 99.EO	.626	(ED-1) Von Duprin
2 EA	Cylinder	20-057 .ICX	.626	(CY-1) Schlage
2 EA	Cylinder	20-061 .ICX	.626	(CY-2) Schlage
4 EA	Cylinder	20-740	.626	(CY-3) Schlage
4 EA	Door Pull	8190HD-0 O	630	(PP-1) Ives
4 EA	Surface Closer	4040XP .SCUSH	.689	(CL-1) LCN Closers
4 EA	Drop Plate	4040XP-18PA	.689	(CL-2) LCN Closers
4 EA	Shoe	4040XP-30	.689	(CL-3) LCN Closers
4 EA	Spacer	4040XP-61	.689	(CL-4) LCN Closers

-ADDED EPT TO POWER ELECTRIFIED EXIT DEVICE. ADVISE IF ACCEPTABLE???????

-CARD READER AND POWER SUPPLY BY SECURITY CONTRACTOR.

OK - AGP

## Heading #: 3.0

## INT. SGL WD/HMF 20 MIN. RATED

1	SGL	Door: 18	Corridor 8 From Custodian 12	LHR	20 MIN
1	SGL	Door: 21	Corridor 8 From Mechanical/Electrical 10	RHR	20 MIN
3' 0" x 7' 0" x 1 3/4" WDD/HMF (20 MIN)					
6 EA	Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	652	(HI-1) Ives	
2 EA	Mortise Lock	L9080 T. 03N	.626	(LO-1) Schlage	
2 EA	Cylinder	30-001	.626	(CY-4) Schlage	
2 EA	Surface Closer	4040XP .RWPA .1BWMS	.689	(CL-11) LCN Closers	
2 EA	Kick Plate	8400 10" x 34"	US32D	(KP-1) Ives	
2 EA	Wall Stop	WS407CCV	630	(ST-1) Ives	
2 EA	Gasketing	5050B x 36" x 84"		(GA-3) National Guard	

# Hardware Schedule

Project ID: 23OK1521-CH - Highland West Junior High Classroom Addition

PROVIDE CARD READER &  
DOOR CONTACT AT DR. #23  
AS REQ'D BY MPS TECHNOLOGY

## Heading #: 3.0A

## INT. SGL WD/HMF 45 MIN. RATED

1	SGL	Door: 9	Corridor 21 From Chase	LHR	45 MIN
1	SGL	Door: 23	I.T. 9 From Chase	RHR	45 MIN

3' 0" x 7' 0" x 1 3/4" WDD/HMF (45 MIN)

6 EA	Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	.652	(HI-1) Ives
2 EA	Mortise Lock	L9080 T .03N	.626	(LO-1) Schlage
2 EA	Cylinder	<del>30-001</del> 23-030	.626	(CY-4) Schlage
2 EA	Surface Closer	4040XP .RWPA .TBWMS	.689	(CL-11) LCN Closers
2 EA	Kick Plate	8400 10" x 34"	US32D	(KP-1) Ives
2 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
2 EA	Gasketing	5050B x 36" x 84"		(GA-3) National Guard

## Heading #: 3.0B

## INT. SGL WD/HMF 20 MIN. RATED

1	SGL	Door: 36	Corridor 8 From Chase	RHR	20 MIN
---	-----	----------	-----------------------	-----	--------

2' 0" x 7' 0" x 1 3/4" WDD/HMF (20 MIN)

3 EA	Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	.652	(HI-1) Ives
1 EA	Mortise Lock	L9080 T .03N	.626	(LO-1) Schlage
1 EA	Cylinder	<del>30-001</del> 23-030	.626	(CY-4) Schlage
1 EA	Surface Closer	4040XP .RWPA .TBWMS	.689	(CL-11) LCN Closers
1 EA	Kick Plate	8400 10" x 22"	US32D	(KP-3) Ives
1 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
1 EA	Gasketing	5050B x 36" x 84"		(GA-3) National Guard

## Heading #: 3.1

## INT. SGL WD/HMF

1	SGL	Door: O14	Principal 31 From Chase	LHR
---	-----	-----------	-------------------------	-----

3' 0" x 7' 0" x 1 3/4" WDD/HMF

3 EA	Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	.652	(HI-1) Ives
1 EA	Mortise Lock	L9080 T .03N	.626	(LO-1) Schlage
1 EA	Cylinder	<del>30-001</del> 23-030	.626	(CY-4) Schlage
1 EA	Surface Closer	4040XP .RWPA .TBWMS	.689	(CL-11) LCN Closers
1 EA	Kick Plate	8400 10" x 34"	US32D	(KP-1) Ives
1 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
3 EA	Silencer	SR64-GRY		(SI-1) Ives

## Heading #: 4.0

## INT. SGL WD/HMF

1	SGL	Door: 34e	Toilet 11 From Stall 11e	LHR
1	SGL	Door: 34f	Toilet 11 From Stall 11f	RHR
1	SGL	Door: O13	Office Corridor To Conference Room 36	LH

3' 0" x 7' 0" x 1 3/4" WDD/HMF

9 EA	Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	.652	(HI-1) Ives
3 EA	Mortise Lock	L9010 .03N	.626	(LO-2) Schlage
3 EA	Kick Plate	8400 10" x 34"	US32D	(KP-1) Ives
3 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
9 EA	Silencer	SR64-GRY		(SI-1) Ives

# Hardware Schedule

Project ID: 23OK1521-CH - Highland West Junior High Classroom Addition

## Heading #: 4.1

## INT. SGL WD/HMF

	1	SGL	Door: 33a	Toilet 11 To Stall 11a	LH
	1	SGL	Door: 33b	Toilet 11 To Stall 11b	LH
	1	SGL	Door: 33c	Toilet 11 To Stall 11c	LH
	1	SGL	Door: 33d	Toilet 11 To Stall 11d	LH
	1	SGL	Door: 33g	Toilet 11 To Stall 11g	RH
	1	SGL	Door: 33h	Toilet 11 To Stall 11h	RH
	1	SGL	Door: 33j	Toilet 11 To Stall 11j	RH
	1	SGL	Door: 33k	Toilet 11 To Stall 11k	RH
	2' 0" x 7' 0" x 1 3/4" WDD/HMF				
24 EA		Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	652	(HI-1) Ives
8 EA		Mortise Lock	L9010 .03N	.626	(LO-2) Schlage
8 EA		Kick Plate	8400 10" x 22"	US32D	(KP-3) Ives
8 EA		Wall Stop	WS407CCV	630	(ST-1) Ives
24 EA		Silencer	SR64-GRY		(SI-1) Ives

## Heading #: 5.0

## INT. SGL WD/HMF

	1	SGL	Door: 20	Custodian 12 From Room	LHR
	1	SGL	Door: 22	Mechanical/Electrical 10 From I.T. 9	RHR
	1	SGL	Door: 32.02	Laboratory 2 From Closet	LHR
	1	SGL	Door: 32.03	Laboratory 3 From Closet	RHR
	1	SGL	Door: 32.06	Laboratory 6 From Closet	RHR
	1	SGL	Door: 32.07	Laboratory 7 From Closet	LHR
	1	SGL	Door: 32.13	Classroom 13 From Closet	RHR
	1	SGL	Door: 32.14	Classroom 14 From Closet	LHR
	1	SGL	Door: 32.17	Laboratory 17 From Closet	RHR
	1	SGL	Door: 32.22	Classroom 22 From Closet	LHR
	1	SGL	Door: 32.23	Classroom 23 From Closet	RHR
	1	SGL	Door: 32.24	Classroom 24 From Closet	LHR
	1	SGL	Door: 32.25	Classroom 25 From Closet	RHR
	1	SGL	Door: O17	Office Corridor To Storage 30	LH
	3' 0" x 7' 0" x 1 3/4" WDD/HMF				
42 EA		Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	652	(HI-1) Ives
14 EA		Mortise Lock	L9466 T .03N	.626	(LO-3) Schlage
14 EA		Cylinder	<del>30-001</del> 23-030	.626	(CY-4) Schlage
14 EA		Wall Stop	WS407CCV	630	(ST-1) Ives
42 EA		Silencer	SR64-GRY		(SI-1) Ives

## Heading #: 5.0A

## INT. SGL WD/HMF

	1	SGL	Door: 19	Custodian 12 From Chase	RHR
	2' 4" x 7' 0" x 1 3/4" WDD/HMF				
3 EA		Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	652	(HI-1) Ives
1 EA		Mortise Lock	L9466 T .03N	.626	(LO-3) Schlage
1 EA		Cylinder	<del>30-001</del> 23-030	.626	(CY-4) Schlage
1 EA		Wall Stop	WS407CCV	630	(ST-1) Ives
3 EA		Silencer	SR64-GRY		(SI-1) Ives

## Heading #: 6.0

## INT. SGL WD/HMF 45 MIN. RATED

	1	SGL	Door: O8	Corridor From Office Corridor	RHR	45 MIN
	3' 0" x 7' 0" x 1 3/4" WDD/HMF (45 MIN)					
3 EA		Hinge, Full Mortise, Hvy Wt	5BB1HW 4-1/2" x 4-1/2"	652	(HI-2) Ives	
1 EA		Fire Rated Rim Exit	<del>99-LBE-F-3'-996L-BE</del> LOCK - ND66T TRL	.626	(ED-1) Von Duprin	SCHLAGE
1 EA		Overhead Stop	904S	630	(OH-2) Glynn-Johnson	
1 EA		Surface Closer	4040XP .RWPA .TBWMS	.689	(CL-11) LCN Closers	
1 EA		Kick Plate	8400 10" x 34"	US32D	(KP-1) Ives	
1 EA		Gasketing	5050B x 36" x 84"		(GA-3) National Guard	
2 EA CLASSIC CORE 23-030 626 SCHLAGE						

# Hardware Schedule

Project ID: 23OK1521-CH - Highland West Junior High Classroom Addition

## Heading #: 7.0

## INT. PAIR WD/HMF 60 MIN. RATED

	1 PRA/PRI Door: 35	Corridor 20 From Existing Corridor	RHR/LHR	60 MIN
2-3' 0" x 7' 0" x 1 3/4" WDD/HMF (60 MIN)				
6 EA	Hinge, Full Mortise, Hvy Wt	5BB1HW 4-1/2" x 4-1/2"	652	(HI-2) Ives
2 EA	Fire Rated Surf Vert Rod	9927.LBE.F .LBR .996L-BE	.626	(ED-8) Von Duprin
2 EA	Surface Closer	4040XP .RWPA .TBWMS	.689	(CL-11) LCN Closers
2 EA	Kick Plate	8400 10" x 34"	US32D	(KP-1) Ives
2 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
2 EA	Electromagnetic Holder	SEM7830	.689	(ST-2) LCN Closers
1 EA	Gasketing	5050B x 72" x 84"		(GA-4) National Guard
1 EA	Astragal	9605A (SET) x 84"		(AS-1) National Guard

IMPORTANT!!! - PLEASE ADVISE IF ACCEPTABLE!!!!!!!!!!!!!!
OK - AGP

-REMOVED FLUSHBOLTS AND COORDINATOR.  
 -CHANGED RIM EXIT DEVICE OT A SURFACE VERTICAL ROD EXIT DEVISE LESS BOTTOM ROD FOR TYPICAL APPLICATION WITH MAGNETIC HOLD OPENS.

-MAGNETIC HOLD OPEN FOR RELEASE IN CASE OF FIRE ALARM ACTIVATION.

## Heading #: 8.0

## INT. SGL WD/HMF

	1 SGL Door: 7	Corridor 21 From Classroom 25	LHR	
	1 SGL Door: 8	Corridor 21 From Classroom 24	RHR	
	1 SGL Door: 10	Corridor 21 From Classroom 23	LHR	
	1 SGL Door: 11	Corridor 21 From Classroom 22	RHR	
	1 SGL Door: 12	Corridor 18 From Classroom 14	RHR	
	1 SGL Door: 13	Corridor 18 From Classroom 13	LHR	
	1 SGL Door: 14	Corridor 18 From Laboratory 17	RHR	
	1 SGL Door: 17	Corridor 8 From Laboratory 15	RHR	
	1 SGL Door: 24	Corridor 8 From Laboratory 6	RHR	
	1 SGL Door: 27	Corridor 8 From Laboratory 2	LHR	
	1 SGL Door: 28	Corridor 8 From Laboratory 3	RHR	
	1 SGL Door: 31	Corridor 8 From Laboratory 7	LHR	
3' 0" x 7' 0" x 1 3/4" WDD/HMF				
36 EA	Hinge, Full Mortise, Hvy Wt	5BB1HW 4-1/2" x 4-1/2"	652	(HI-2) Ives
12 EA	Mortise Lock	L9070 T .03N	.626	(LO-4) Schlage
12 EA	Cylinder	<del>30-001</del> 23-030	.626	(CY-4) Schlage
12 EA	Surface Closer	4040XP .HWPA .TBWMS	.689	(CL-12) LCN Closers
12 EA	Kick Plate	8400 10" x 34"	US32D	(KP-1) Ives
12 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
36 EA	Silencer	SR64-GRY		(SI-1) Ives

## Heading #: 9.0

## INT. PAIR HMD/HMF

	1 PRA/PRI Door: 2	Vestibule 26 From Corridor 21	RHR/LHR	
	1 PRA/PRI Door: 4	Vestibule 19 From Corridor 20	RHR/LHR	
	1 PRA/PRI Door: 6	Vestibule 1 From Corridor 8	RHR/LHR	
2-3' 0" x 7' 0" x 1 3/4" HMD/HMF				
9 EA	Hinge, Full Mortise, Hvy Wt	5BB1HW 4-1/2" x 4-1/2"	652	(HI-2) Ives
3 EA	Push Plate	8200-4x16	630	(PP-2) Ives
3 EA	Pull Plate	8303-0-4x16	630	(PP-3) Ives
3 EA	Surface Closer	4040XP .HWPA .TBSRT	.689	(CL-13) LCN Closers
3 EA	Kick Plate	8400 10" x 35"	US32D	(KP-2) Ives
3 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
9 EA	Silencer	SR64-GRY		(SI-1) Ives

# Hardware Schedule

Project ID: 23OK1521-CH - Highland West Junior High Classroom Addition

## Heading #: 10.0

## INT. SGL WD/HMF

1	SGL	Door: 15	Laboratory 17 From Storage 16	LHR
1	SGL	Door: 16	Laboratory 15 From Storage 16	RHR
1	SGL	Door: 25	Laboratory 6 From Storage 4	LHR
1	SGL	Door: 26	Laboratory 2 From Storage 4	RHR
1	SGL	Door: 29	Laboratory 3 From Storage 5	LHR
1	SGL	Door: 30	Laboratory 7 From Storage 5	RHR
1	SGL	Door: O9	Office Corridor To Office 38	LH
1	SGL	Door: O11	Office Corridor To Office 37	LH
1	SGL	Door: O16	Office Corridor To Principal 31	RH
3' 0" x 7' 0" x 1 3/4" WDD/HMF				

27 EA	Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	652	(HI-1) Ives
9 EA	Mortise Lock	L9050 .T .03N	.626	(LO-5) Schlage
9 EA	Cylinder	<del>30-001</del> 23-030	.626	(CY-4) Schlage
9 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
27 EA	Silencer	SR64-GRY		(SI-1) Ives

## Heading #: 11.0

## INT. SGL WD/HMF

1	SGL	Door: O10	Office Corridor To Toilet 35	LH
1	SGL	Door: O12	Office Corridor To Toilet 34	RH
1	SGL	Door: O15	Principal 31 To Toilet 33	LH
3' 0" x 7' 0" x 1 3/4" WDD/HMF				

9 EA	Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	652	(HI-1) Ives
3 EA	Mortise Lock	L9444 .03N	.626	(LO-6) Schlage
3 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
9 EA	Silencer	SR64-GRY		(SI-1) Ives

## Heading #: 12.0

## EXT. PAIR HMD/HMF

1	PRA/PRI	Door: 1	Exterior From Vestibule 26	RHRA/LHR
1	PRA/PRI	Door: 3	Exterior From Vestibule 19	RHRA/LHR
1	PRA/PRI	Door: 5	Exterior From Vestibule 1	RHRA/LHR
2-3' 0" x 7' 0" x 1 3/4" HMD/HMF				

2 EA KICKPLATES 08400 10"X34" 630 IVE OR EQUAL				
6 EA	Continuous Hinge	224HD 83"	.628	(HC-1) Ives
3 EA	Mullion	KR4954 7'6"	.689	(MU-1) Von Duprin
3 EA	Rim Exit Device	.CD 99.EO .3'	.626	(ED-5) Von Duprin
3 EA	Rim Exit Device	.CD 99.NLOP .110MD-NL	.626	(ED-6) Von Duprin
3 EA	Cylinder	20-057 .ICX	.626	(CY-1) Schlage
9 EA	Cylinder	20-061 .ICX	.626	(CY-2) Schlage
12 EA	Cylinder	20-740	.626	(CY-3) Schlage
6 EA	Door Pull	8190HD-0 O	630	(PP-1) Ives
6 EA	Push Plate	8200-4x16	630	(PP-2) Ives
6 EA	Surface Closer	4040XP .SHCUSH .TBSRT	.689	(CL-7) LCN Closers
3 EA	Threshold	896V x 72"		(TH-1) National Guard
3 EA	Gasketing	700SA x 72" x 84"		(GA-1) National Guard
3 EA	Drip Strip	16A x 76"		(GA-2) National Guard
6 EA	Sweep	C627A x 36"		(SW-1) National Guard

CARD READER / DOOR CONTACTS BY OTHERS?

## Heading #: 13.0

## INT. SGL WD/HMF

1	SGL	Door: O7	Corridor 28 To Room	LH
3' 0" x 7' 0" x 1 3/4" WDD/HMF				

3 EA	Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"	652	(HI-1) Ives
1 EA	Mortise Lock	L9050 .T .03N	.626	(LO-5) Schlage
1 EA	Cylinder	<del>30-001</del> 23-030	.626	(CY-4) Schlage
1 EA	Surface Closer	4040XP .RWPA .TBWMS	.689	(CL-11) LCN Closers
1 EA	Wall Stop	WS407CCV	630	(ST-1) Ives
3 EA	Silencer	SR64-GRY		(SI-1) Ives

# Hardware Schedule

Project ID: 23OK1521-CH - Highland West Junior High Classroom Addition

## Heading #: 13.0A

## INT. SGL WD/HMF 45 MIN. RATED

	1 SGL	Door: O6	Corridor 28 From Reception 29	LHR	45 MIN
		3' 0" x 7' 0" x 1 3/4" WDD/HMF (45 MIN)			
3 EA	Hinge, Full Mortise	5BB1 4-1/2" x 4-1/2"		652	(HI-1) Ives
1 EA	Mortise Lock	L9050 .T .03N		.626	(LO-5) Schlage
1 EA	Cylinder	30-001		.626	(CY-4) Schlage
1 EA	Surface Closer	4040XP .RWPA .TBWMS		.689	(CL-11) LCN Closers
1 EA	Wall Stop	WS407CCV		630	(ST-1) Ives
1 EA	Gasketing	5050B x 36" x 84"			(GA-3) National Guard

23-030

DOOR CONTACT /  
CARD READER BY  
OTHERS?

## Heading #: 14.0

## INT. SGL ALD/ALF

	1 SGL	Door: O5	Vestibule 27 From Reception 29	LHR	
		3' 0" x 7' 0" x 1 3/4" ALD/ALF			
1 EA	Intermediate Pivot	7215-INT		US26D	(PV-1) Ives
1 Set	Pivot Set	7215-SET		US26D	(PV-2) Ives
1 EA	Electric Power Transfer	EPT10		.689	(PT-1) Von Duprin
1 EA	Rim Exit Device	.QEL 99.EO		.626	(ED-1) Von Duprin
1 EA	Door Pull	8190HD-0 O		630	(PP-1) Ives
1 EA	Surface Closer	4040XP .SCUSH		.689	(CL-1) LCN Closers
1 EA	Drop Plate	4040XP-18PA		.689	(CL-2) LCN Closers
1 EA	Shoe	4040XP-30		.689	(CL-3) LCN Closers
1 EA	Spacer	4040XP-61		.689	(CL-4) LCN Closers

-ADDED EPT TO POWER ELECTRIFIED EXIT DEVICE. ADVISE IF ACCEPTABLE???????

-CARD READER AND POWER SUPPLY BY SECURITY CONTRACTOR.

OK - AGP