



1 WATERLINE SITE PLAN
1" = 30'-0"

LEGEND:
NW ——— NEW WATER LINE
EV ——— EXISTING WATER LINE

- GENERAL NOTES:
- EXISTING UNDERGROUND UTILITY LOCATIONS & CONTOUR INFORMATION HAVE BEEN OBTAINED FROM THE BEST AVAILABLE SOURCES. THE CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONS PRIOR TO COMMENCING WORK & COORDINATE W/ ARCHITECT.
 - LOCATE & PROJECT EXISTING UNDERGROUND UTILITIES TO REMAIN. PROVIDE SLEEVES THROUGH NEW CONCRETE FOUNDATIONS & PROVIDE WATERTIGHT INSTALLATION. COORDINATE W/ ARCHITECT & OWNER.
 - REFER MEP FOR ADDITIONAL INFORMATION CONCERNING CONNECTIONS TO EXISTING UTILITIES.
 - CONNECT NEW 2" CW TO EXISTING WATER LINE SERVICE. RE: PLUMBING FOR CONTINUATION. PROVIDE PVC (ASTM D 785 OR APPROVED MATERIAL LISTED IN IPC SECTION 6) SLEEVES 5 FEET HORIZONTALLY FROM SEWER PIPE CENTERLINE WHERE REQUIRED. PATCH / REPAIR ALL PAVING AS REQUIRED - MATCH EXISTING

- EXISTING FIRE HYDRANT EFH
- CONNECT TO EXISTING