

## **GENERAL NOTES**

COORDINATE WORK WITH ALL TRADES ON SITE.

MAINTAIN MINIMUM OF 10'-0" CLEAR BETWEEN EXHAUST AND INTAKE VENTS WITH MECHANICAL EQUIPMENT AND OTHER ROOF OPENINGS.

1 COORDINATE INSTALLATION OF PLUMBING VENTS WITH ROOFING CONTRACTOR. INSTALL VENT A MINIMUM 10'-0" FROM ANY OPENINGS, EQUIPMENT, INTAKES OR EXHAUST VENTS.

2 COORDINATE INSTALLATION OF 3" GAS WATER HEATER CONCENTRIC VENT WITH ROOFING CONTRACTOR AND PER MANUFACTURER'S RECOMMENDATIONS. INSTALL VENT A MINIMUM 10'-0" FROM ANY OPENINGS, EQUIPMENT, INTAKES, EXHAUST VENTS AND ROOF EDGE.



SUITE 210 MOORE, OK. 73160 405.735.3477 AGP@theAGP.net www.theAGP.net

AGP

the Abla Griffin

Partnership L.L.C.

201 N. BROADWAY

WDB ENGINEERING

SALAS O'BRIEN

MECHANICAL / ELECTRICAL



MOORE PUBLIC SCHOOLS **BOARD OF EDUCATION** MOORE, OKLAHOMA



LOCKER ROOM **ADDITION MOORE WEST** JUNIOR HIGH SCHOOL

sheet no:

Salas O'Brien

2600 Van Buren St., Suite 2635 Norman, OK 73072 Salas O'Brien Registration: CA# 7058 Expiration Date: 6/30/2025 Salas O'Brien Project Number: 2023-04636-00 OWNERSHIP USE OF DOCUMENTS:

AGP EXPRESSLY RESERVES ITS COPYRIGHT AND OTHER PROPERTY RIGHTS OF ALL PLANS AND DRAWINGS DESIGNED AND/OR PRODUCED. PLANS AND DRAWINGS ARE NOT TO BE REPRODUCED IN ANY FORM OR MANNER WITHOUT THE EXPRESSED WRITTEN CONSENT OF AGP.