



P. O. Box 892245 • OKC, OK 73189
 OFFICE: 405-735-3992 • CELL: 405-570-7881

Request For Information

Date	December 21st, 2023
Project	Moore West JH Locker Room Addition
Subcontractor / Supplier	
	Address:
Manufacturer	
Spec. Section	RFI #2 Plumbing
Notes Below	
<p>Clay / Mike please see the RFI request from Watson Plumbing below.</p> <p>On page A 301 in a boxed note in section 1, a direction of extending existing plumbing and mechanical to accommodate new construction. I do not see this in any of the plumbing pages. Is this work in the plumbing scope?</p> <p>Also, Page PD 101 shows disconnection of existing storm drains. I do not see any information for re connection for civil or plumbing. Disconnect and cap out side of the building pad?</p> <p style="color: red;">1. Extend vents, etc as required for new construction. 2. Existing storm drains "daylight" in new building pad remove storm drain pipes completely.</p> <p>Thanks Clay Griffin 12-21-23</p>	

Submitted By: Chris Dysart