



P. O. Box 892245 • OKC, OK 73189
OFFICE: 405-735-3992 • CELL: 405-570-7881

Request For Information

| | |
|---|------------------------------------|
| Date | December 27, 2023 |
| Project | Moore West JH Locker Room Addition |
| Subcontractor / Supplier | |
| | Address: |
| Manufacturer | |
| Spec. Section | RFI #3 Electrical |
| Notes Below | |
| Clay / Mike | |
| Please see RFI request from Messer Electric below: | |
| On sheet E401 on the one-line diagram it states for us to install a new breaker in a existing 600amp panel but this drawing does not give us the designation or the location of this panel. Can you help with this? | |
| <p>Existing unlabeled Panel "##" is located in the attached football locker room just South of the addition. - Kyle Wanzer SOBE 12/28/2023</p> | |

Submitted By: Chris Dysart



STW

MOORE WEST

TIGERS

TIGERS

W

PWT

TIGERS