

**MOORE PUBLIC SCHOOLS -
MPS CHILD DEVELOPMENT CENTER**
Moore Public Schools - Moore, Oklahoma
AGP - Moore, Oklahoma

CONSTRUCTION BULLETIN NO. 9

April 18, 2025

1. DOOR G1 (GENERATOR ADDITION TORNADO DOORS & FRAME) TO BE EQUAL TO PRODUCTS SPECIFIED IN SECTION 08310 – TORNADO DOORS AND AS INDICATED ON SHEETS GEN-101, 3A201 & S701 WHICH ARE A PART OF THE CONTRACT DOCUMENTS / PROJECT MANUAL. CONSTRUCTION MANAGER SHALL FIELD VERIFY OPENING AND ADJUST / FABRICATE DOORS AND FRAME TO FILL VOID AS PER STRUCTURAL DRAWING S701. COORDINATE WITH ARCHITECT.
2. HARDWARE FOR TORNADO DOOR G1 SHALL BE EQUAL TO SET T2 AS SPECIFIED BELOW:

Hardware Group No. T2 - Door #G1: Provide each PR exterior tornado door(s) with the following:

Quantity		Description	Model Number	Finish	Mfr
6	EA	HINGE	5BB1HW 4.5 X 4.5	652	IVE
2	EA	FIRE EXIT HARDWARE	WS9827/9927L 996L-R/V		
			LENGTH AS REQUIRED	626	VON
2	EA	RIM CYLINDER	20-057 ICX	626	SCH
1	EA	MORTISE CYLINDER	20-061 ICX	626	SCH
3	EA	CLASSIC CORE	30-001	626	SCH
1	SET	ASTRAGAL	9115A HEIGHT AS REQ	AL	NGP
2	EA	SURFACE CLOSER	4041 OR P4041 MTG BRKTS,	SPCRS &	
			PLATES AS REQ	689	LCN
2	EA	KICK PLATE	8400 10" X 2" LDW	630	IVE
2	EA	FLOOR STOP	WS407CCV OR FS436 AS REQ		
				628	IVE
1	SET	SEALS	5050B H & J	BLK	NGP
2	EA	DOOR SWEEP	101VA LGTH AS REQ	AL	NGP
1	EA	THRESHOLD	892V LGTH AS REQ	AL	NGP

SUPPLIER TO VERIFY HARDWARE SPECIFIED AND REVISE AS NECESSARY TO MEET THE REQUIREMENTS OF ICC 500-2018.

END OF CONSTRUCTION BULLETIN NO. 9