



P. O. Box 892245 • OKC, OK 73189
OFFICE: 405-735-3992 • CELL: 405-570-7881

Request For Information

Date	February 27 th , 2026
Project	Wayland Bonds 2025 HVAC
Subcontractor / Supplier	
	Address:
Manufacturer	
Spec. Section	RFI #2 Mechanical
Notes Below	
<p>Clay / Mike please see the RFI request from Streets Mechanical below.</p> <p>Thanks</p> <ul style="list-style-type: none">• Does the piping for the heat exchangers, cooling tower, etc need to be HDPE or can it be steel?• Please clarify if we are using the existing valves and lines for the new wshp units or do we need to provide new? <div style="border: 2px solid red; padding: 5px;"><p>1. HDPE is not required. Use steel for new pipes. 2. Reuse existing valves and piping for WSHPs. Provide new BACnet controls and monitoring. - Kaitlyn Faust SOBE 03/02/2026</p></div>	

Submitted By: Chris Dysart